

() RENEWAL

ULSTER COUNTY DEPARTMENT OF HEALTH
ENVIRONMENTAL HEALTH SERVICES
239 GOLDEN HILL LANE
KINGSTON, NY 12401

() FORMERLY:

PERMIT TO CONSTRUCT A WASTE DISPOSAL SYSTEM

THIS PERMIT IS ISSUED UNDER THE PROVISIONS OF ARTICLE VI, SECTION 6.4.0 OF THE ULSTER COUNTY SANITARY CODE. **PERMITS ARE NON-TRANSFERABLE.**

This Permit is Valid for a *Two Year* Period – Date of Issuance: 05/16/2024

1. APPLICANT

Allison & David Wolfe

2. ADDRESS OF APPLICANT

c/o Medenbach & Eggers, P.C.
4305 US Highway 209
Stone Ridge, NY 12484

3. LOCATION OF PROJECT

Wyncoop Road - proposed lot 2

4. TOWNSHIP

Olive

5. TYPE OF OWNERSHIP

Single Family - 3 bedroom

6. TAX IDENTIFICATION NUMBER

Part of 60.2-3-15

DESCRIPTION OF WORKS

INSTALLATION OF: System Type: Shallow Absorption Trenches

Minimum separation of the absorption field 100 feet from well, (150 feet if seepage pit), 100 feet from a stream or water course, and 10 feet from the property line.

All systems shall be designed / constructed in conformance with all applicable rules and regulations. (Appendix 75-A "Wastewater Treatment Standards – Individual Household Systems", latest revision and / or DEC Design Standards for Wastewater Treatment Works, latest revision.)

Well log to be submitted prior to final approval.

Well construction to be in accordance with Appendix 5-B, Standards for Water Wells, November 23, 2005.

The sewage system must be installed in accordance with the plans submitted by Medenbach & Eggers, P.C. and approved / accepted by this department on 05/16/2024.

A New York State Licensed P.E., Architect, or Exempt Land Surveyor must certify that the sewage system has been installed in accordance with the approved / accepted plan.

23-074

MB

2014

 P.E.

 P.E. 05/16/24

cc: NYC WATERSHED - () Ashokan, () Delaware, () Rondout/Neversink

FULLY DELEGATED ()

JOINT REVIEW AND APPROVAL ()