

December 18, 2024



Kimberly Snyder  
North Engineers & Design Associates  
P.O. Box 276  
West Hurly, NY 12491

**Rohit T. Aggarwala**  
Commissioner

Re: Ashokan Store-It LLC.  
Stormwater Pollution Prevention Plan (SWPPP)  
7 Ridge Road; Town of Olive; Ulster County  
Tax Map No.: 46.5-3-6.110  
Ashokan Reservoir Drainage Basin  
DEP Log # 2000-AS-1227-OT.1

Dear Ms. Snyder:

**Paul V. Rush, P.E.**  
Deputy Commissioner

Bureau of Water Supply  
prush@dep.nyc.gov

71 Smith Avenue  
Kingston, New York  
12401

T: (845) 340-7800  
F: (845) 334-7175

The New York City Department of Environmental Protection (DEP) has met with you on the above-referenced property on 10/07/2024 to discuss the proposed development of four proposed self-storage units. According to the information you provided (sketch plan), the proposal involves construction of four new self-storage units, gravel driveway and a retaining wall. Based on our conversation and the sketch plan, it does not appear that the proposed project will disturb greater than 2 acres of land or include new impervious surfaces within 100-feet of a watercourse or create an impervious surface totaling over 40,000 square feet in size. As such and in accordance with the "*Rules and Regulations for the Protection from Contamination, Degradation, and Pollution of the New York City Water Supply and Its Sources*" (NYC Watershed Rules and Regulations), no DEP approved SWPPP is required.

If you have any questions regarding this matter, please contact me at (845) 340-7222.

Sincerely,

A handwritten signature in blue ink, appearing to read "Curt Field".

Curt Field  
Associate Project Manager  
Kingston Project Review